

Residential Water Meter Package Installation Self Checklist

1) Right angle meter valve and stainless steel pipe insert (PEX piping only) have been installed and the restraining screw has been tightened?	<input type="checkbox"/>
2) Water meter, dual check valve, and meter gaskets have been installed?	<input type="checkbox"/>
3) Expansion tank has been installed on a cold-water line and the air pressure in the bladder charged equal to static line pressure?	<input type="checkbox"/>
4) Meter wire is installed from the water meter to the hydro meter location and between 1.2M-1.5M above final grade?	<input type="checkbox"/>
5) Water service and plumbing are adequately supported?	<input type="checkbox"/>
6) Water service has been pressure tested and inspected by the City's Building Department?	<input type="checkbox"/>
7) The water meter, curb stop valve, and SmartPoint location are safely accessible?	<input type="checkbox"/>

If the above seven items have been completed, please request your inspection and water turn-on appointment by e-mailing WaterMetering@barrie.ca or calling 705-739-4220 x6169. A minimum notice of two business days is required for an appointment.

A Missed Appointment Fee will be levied if the appointment cannot be completed. Reasons for a Missed Appointment Fee include, but are not limited to:

- Installation does not conform to the Residential Water Meter Package Installation drawing (Infrastructure Standard W532) and Drinking Water Infrastructure Design Standard. See barrie.ca/InfrastructureStandards.
- Items listed on the checklist above have not been completed.
- No representative on site during scheduled appointment time.
- Damaged water service/metering appurtenances.
- No heat provided during winter months.

This checklist is included in the Residential Water Meter Package and is maintained by the City's Water Operations Branch. For more information, please visit barrie.ca/WaterMeters.

