



NOTES:

1. MIN 300mm CLEAR SPACE REQUIRED FROM CENTER OF METER TO EXTERIOR WALL(ONE WALL), MIN. 600mm CLEAR SPACE REQUIRED (THREE SIDES)
2. AVERAGE SIZE PERSON SHOULD BE ABLE TO ACCESS METER.
3. PROVIDE SUPPORT FOR THE METER AS REQUIRED.
4. METER WIRE TO BE BROUGHT TO OUTSIDE OF BUILDING BESIDE HYDRO METER, OR ON NEAREST EXTERIOR WALL TO WATER METER IF HYDRO METER IS UNAVAILABLE.
5. NO CONNECTIONS PERMITTED UPSTREAM OF THE WATER METER..
6. METER TO BE INSPECTED AND SEALED PRIOR TO OCCUPANCY, CALL WATER OPERATIONS BRANCH FOR INSPECTION AND SEAL OF WATER METER.
7. PIPING SUPPORT REQUIRED TO CITY OF BARRIE SATISFACTION.
8. WATER METERS LOCATED IN A CRAWL SPACE, UNDER STAIR LANDING, IN WALLS OR OTHER INACCESSIBLE AREAS WILL NOT BE ACCEPTED.
9. A FLAT SURFACE MUST BE PROVIDED FOR THE INSTALLATION OF THE EXTERIOR REMOTE READING DEVICE (SMARTPOINT).
10. IF METER WIRE PASSES THROUGH ANOTHER DWELLING OR IS RUN UNDER THE FLOOR IT MUST BE PLACED IN A DEDICATED CONDUIT.