



1. FENCE LOCATIONS AND DIMENSIONS MUST BE IN ACCORDANCE WITH APPROVED ENGINEERING AND/OR LANDSCAPE PLANS.
2. RUNS FOR FENCING OF MORE THAN 150m ARE TO HAVE A 89mm DIA INTERMEDIATE STRAINING POST AND (2) TWO 42.9mm DIA BRACE RAILS SIMILAR TO THOSE USED FOR TERMINAL POSTS.
3. TIE WIRES - #9 GAUGE HARD ALUMINUM (REFERENCE 5052-H18-ASTM-BS11 FASTENERS).
4. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS NOTED.
5. ALL HARDWARE TO BE HOT DIP GALVANIZED.
6. NO GATES ARE PERMITTED FROM PROPERTY.
7. ONLY USE SCHEDULE 40 GALVANIZED PIPE.
8. FENCING TO BE INSTALLED SOLELY ON MUNICIPAL PROPERTY WITH AN INSET OF 150 TO FENCE CENTRE LINE.
9. THE TOP OF WIRE MESH SHALL BE KNUCKLED OVER SUCH THAT NO SHARP PROJECTIONS ARE VISIBLE OVER THE TOP RAIL.

The City of  
**BARRIE**  
STANDARD DETAIL

## 1.25m CHAIN LINK FRONTAGE RETURN FENCING

REV No.	DATE: JUNE 2015
<b>1</b>	SCALE: N.T.S.

BSD-1209

APPROVED

DATE: *June 11/15*  
*J.M.W.*  
DIRECTOR OF ENGINEERING