



1. FENCE LOCATIONS AND DIMENSIONS MUST BE IN ACCORDANCE WITH APPROVED ENGINEERING AND/OR LANDSCAPE PLANS.
2. RUNS FOR FENCING OF MORE THAN 150m ARE TO HAVE AN 89mm DIAMETER INTERMEDIATE STRAINING POST AND (2) TWO 42.9mm DIAMETER BRACE RAILS SIMILAR TO THOSE USED FOR TERMINAL POSTS.
3. TIE WIRES - #9 GAUGE HARD ALUMINUM (REFERENCE 5052-H18-ASTM-BS11 FASTENERS).
4. ALL HARDWARE TO BE HOT DIP GALVANIZED.
5. NO GATES ARE PERMITTED FROM PROPERTY.
6. ONLY USE SCHEDULE 40 GALVANIZED PIPE.
7. THE TOP OF WIRE MESH SHALL BE KNUCKLED OVER SUCH THAT NO SHARP PROJECTIONS ARE VISIBLE OVER THE TOP RAIL.
8. ALL DIMENSIONS ARE IN MILLIMETRES.
9. DETAIL TO BE USED IN CONJUNCTION WITH BSD-1250 AND BSD-1251.

Barrie
STANDARD DETAIL

TENNIS COURT CHAIN LINK
FENCE

REV No. 2
DATE: OCT 2017
SCALE: N.T.S.

BSD-1212
FORMERLY BSD-64

APPROVED
DATE: Oct 10 17
R. Sults
DIRECTOR OF ENGINEERING