



1. ASPHALT SHALL BE PLACED AND SPREAD USING A MECHANICAL PAVER.
2. ASPHALT LAYERS (AFTER ROLLING) TO BE COMPACTED TO A MINIMUM 97% S.P.M.D.D.
3. IN THE EVENT OF UNSUITABLE SUB-GRADE MATERIAL, BASE IS TO BE OVER-EXCAVATED AND BACKFILLED WITH GRANULAR 'B' COMPACTED TO 98% S.P.M.D.D.
4. ALL BACKFILL TO BE COMPACTED IN LIFTS OF 100mm.
5. ENSURE POSITIVE DRAINAGE.
6. TAMP ALL EDGES TO A FIRM 45 DEGREE BEVEL.
7. ALL DIMENSIONS ARE IN MILLIMETRES.
8. REFER ALSO TO BSD-1272.

Barrie
STANDARD DETAIL

TYPICAL PARK WALKWAY
SECTION WITH CROSS SLOPE

REV No.

DATE: OCT 2017

2

SCALE: N.T.S.

BSD-1273

FORMERLY BSD-37

APPROVED

DATE *Oct 10/17*

[Signature]
DIRECTOR OF ENGINEERING