



1. TYPICAL SETBACK FROM WALKWAY OR HARD SURFACE IS 1000mm.
2. POLE FOUNDATION SUBJECT TO SPECIFIC SITE SOIL CONDITIONS.
3. CONCRETE POLE BY UTILITY STRUCTURES INC., PRE-STRESSED, TAPERED, OCTAGONAL IN AN ECLIPSE FINISH (BLACK) WITH MOUNTING FOR A SIDE MOUNTED FIXTURE.
4. LUMINAIRE BY CREE LIGHTING X - AL SERIES (BLACK), 120V, 37 WATT LAMP DRIVER WITH A 20 LED LAMP, AND PHOTOCCELL INCLUDED.
5. LUMINAIRE TO HAVE AN ADJUSTABLE ARM MOUNTING STRUCTURE, AND TO HAVE A TYPE 2 MEDIUM LIGHT DISTRIBUTION.
6. INSTALLER TO COORDINATE INSPECTION WITH ELECTRICAL CONSULTANT AND LOCAL HYDRO AUTHORITY, AND PROVIDE SAFETY CERTIFICATE TO THE CITY OF BARRIE.
7. ALL DIMENSIONS ARE IN MILLIMETRES.
8. PROPOSED MATERIAL EQUIVALENTS MUST BE APPROVED THROUGH THE CITY OF BARRIE'S APPROVED PRODUCT APPLICATION PROCESS.

**APPROVED**

DATE . . . *Oct 10/17*

*[Signature]*

DIRECTOR OF ENGINEERING

REV No. DATE: OCT 2017

2

SCALE: N.T.S.

**BSD-1350**

FORMERLY BSD-73



STANDARD DETAIL

**PARK WALKWAY  
LIGHTING ASSEMBLY AND  
DUCTBANK**