



NOTES:

1. EXTENSION REQUIRED WHEN DISTANCE FROM THE TOP OF VALVE TO FINISHED GRADE IS MORE THAN 1.7m.

APPROVED

DATE . 6 Feb 2015 . . .

J.M. Work
DIRECTOR OF ENGINEERING

City of
BARRIE
STANDARD DETAIL

**VALVE STEM EXTENSION
IN VALVE BOX**

REV No.	DATE: FEB 2015
1	SCALE: N.T.S.

BSD-511
(PREVIOUSLY BSD-46)