



NOTE:

1. TYPICAL DETAIL ONLY, THERMAL PROTECTION SHALL BE DESIGNED "SITE SPECIFIC" PER MINISTRY OF ENVIRONMENT DESIGN GUIDELINES.
2. MINIMUM TRENCH WIDTH TO BE O.D. PLUS 600mm MAX TRENCH WIDTH TO BE O.D. PLUS 750mm AS PER OHSA GUIDELINES
3. INSULATING THE BOTTOM OF THE TRENCH MAY BE REQUIRED IF STORMWATER INFRASTRUCTURE IS UNDER WATERMAIN
4. ALL UNITS IN MILLIMETERS UNLESS OTHERWISE NOTED.