



NOTES:

1. MATERIAL FOR LOWERING SHALL BE DUCTILE IRON IF EXISTING MATERIAL IS METALLIC.
2. UNITS IN MILLIMETERS UNLESS OTHERWISE NOTED.
3. ALL JOINTS TO BE MECHANICALLY RESTRAINED, INCLUDING JOINTS ON EXISTING WATERMAIN.



LOWERING DETAIL AT NEW OR EXIST. WATERMAIN CROSSING OF NEW OR EXIST. SANITARY SEWER

REV No.	DATE: FEB 2015
1	SCALE: N.T.S.
BSD-518	

APPROVED
 DATE: 6 Feb 2015
[Signature]
 DIRECTOR OF ENGINEERING