



NOTES:

1. CONCRETE ENCASED MAINS SHALL BE SUPPORTED WITH CONCRETE TO UNDERSIDE OF MAIN. BOND BREAKER IS TO BE USED BETWEEN THE TWO SURFACES.

2. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.

APPROVED

DATE: 6 Feb 2015

J. M. ...
DIRECTOR OF ENGINEERING

City of
BARRIE
STANDARD DETAIL

**SUPPORT FOR
WATERMAINS LARGER
THAN 300mm DIAMETER**

REV No. 1
DATE: FEB 2015
SCALE: N.T.S.

BSD-520
(PREVIOUSLY BSD-53)