



**NOTES:**

1. ALL PLUMBING TO CONFORM TO ONTARIO BUILDING CODE.
2. STORM SEWERS SHALL BE CONSTRUCTED WITH BEDDING AS PER OPSD-802.010 (GRAN. 'A' EMBEDMENT MATERIAL) FOR FLEXIBLE PIPES AND OPSD-802.030 OR 802.031 CLASS B (GRAN. 'A' BEDDING MATERIAL) FOR RIGID PIPE UNLESS OTHERWISE APPROVED BY THE DIRECTOR OF ENGINEERING.
3. REQUIRES ABS TO PVC ADAPTER CONNECTION.
4. POLYVINYL CHLORIDE SEWER PIPE (PVC) STORM PIPE B182.1 B181.2, B182.4
5. ACRYLONITRILE-BUTADIENE-STYRENE (ABS) PIPE B181.1

CITY OF BARRIE STANDARD

APPROVED

DATE: 09 11 05

*R. W. McArthur*  
DIRECTOR OF ENGINEERING

SCALE: N.T.S.

**FOUNDATION DRAIN OUTLET  
SUMP PUMP TO STORM SEWER**

NO.

REVISION

APR'D

DATE

**BSD-75B**