



RIGID DUCTS, CONCRETE ENCASED

NOTES:

1. GROUT TO BE PLACED FULL DEPTH, FLUSH WITH BOTH WALLS.
2. GROUT TO BE PLACED WITHIN STEEL PIPE, AROUND ALL DUCTS, TO A MINIMUM DEPTH OF 75mm.
3. ALL DIMENSIONS ARE IN MILLIMETRES OR METRES UNLESS OTHERWISE SHOWN.