



**NOTES:**

1. FOR DUCT ENTRY DETAILS SEE BSD-805.
2. FOR HANDHOLES WITH METAL FRAMES, GROUND WIRE SHALL BE ATTACHED TO FRAME USING A GROUND LUG SUITABLE FOR #6 AWG STRANDED COPPER WIRE.
3. FOR HANDHOLES WITH METAL COVERS AND NON METALLIC FRAMES, THE GROUND WIRE SHALL BE ATTACHED TO THE HANDHOLE COVER USING A GROUND LUG SUITABLE FOR #6 AWG COPPER WIRE.
4. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN.

**APPROVED**  
 DATE *June 4/15*  
*[Signature]*  
 DIRECTOR OF ENGINEERING

*City of*  
**BARRIE**  
 STANDARD DETAIL

**ELECTRICAL HANDHOLES  
 GENERAL INSTALLATION  
 REQUIREMENTS**

REV No. **1**    DATE: MAY 2015  
 SCALE: N.T.S.

**BSD-804**