



NOTES:

1. DUCT ENTRY HOLES TO BE FILLED WITH GROUT, FULL DEPTH, FLUSH WITH BOTH WALLS.
2. RIGID DUCTS TERMINATING IN MAINTENANCE HOLES, HANDHOLES, OR OTHER PERMANENT OPENINGS OF UNDERGROUND SYSTEMS SHALL BE PROVIDED WITH AN END BELL. RIGID DUCTS ENTERING THE BOTTOM OF HANDHOLES SHALL BE FITTED WITH RPVC COUPLING.
3. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN.

City of  
**BARRIE**  
STANDARD DETAIL

**ELECTRICAL HANDHOLES  
ENTRY OF DIRECT BURIED AND  
ENCASED DUCTS**

REV No.

1

DATE: MAY 2015

SCALE: N.T.S.

**BSD-805**

APPROVED

DATE June 4/15

*[Signature]*  
DIRECTOR OF ENGINEERING