

### BILL OF MATERIALS

Item No.	QTY.	Description	Manufacturer	Part No.
1	1	Main Breaker 100A 2P	SQ.D	QO2100
2	5	Branch Breakers 35A 1Pole	SQ.D	QO135
11	1	Branch Breaker 60A 1 Pole	SQ.D	QO160
3	1	Solid Neutral Assembly 100A min.	SQ.D	CH200SN
4	1	Ground Lug For #6 Copper Wire		
5	1	Ground Lug for #2/0 Copper	T&B	ADR 25-21
6	1	Secondary Lighting Arrester	GE	9L15ECB001
7	1	Drip Shield	B&M	Custom

**NOTES:**

1 - TYPE 3M NAMEPLATE SEE DETAIL BELOW.

2 - PANEL IS SERVICE ENTRANCE READY.

(MANUFACTURER)  
TYPE 3M  
100 AMP 120/240 VOLT  
(DATE OF MANUFACTURE)

**APPROVED**  
DATE *JUN 4, 2015.*  
*[Signature]*  
DIRECTOR OF ENGINEERING

*City of*  
**BARRIE**  
STANDARD DETAIL

**LS3M SUPPLY CONTROL  
CABINET ASSEMBLY TYPE  
3M EQUIPMENT LIST**

REV No.	DATE: MAY 2015
1	SCALE: N.T.S.
<b>BSD-812</b>	