



NOTES:

1. TO BE USED IN CONJUNCTION WITH BSD-828 AND BSD-830
2. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN
3. HOLE TO BE AUGERED OR "HYDRO VAC"
4. FOUNDATION OF GRANULAR 'A' COMPACTED TO 95% SPMDD
5. SET POLE ENSUING BASE OF POLE IS AT FINISHED GRADE
6. BACKFILL AND TAMP BOTTOM 450mm BEFORE FINAL PLUMBING OF POLE THEN CONTINUE TO BACKFILL
7. USE NON-SHRINK MATERIAL FOR BACKFILL FOR TAMPING EVERY 300mm UP TO THE LEVEL OF EXISTING UNDERBASE



STANDARD DETAIL

DECORATIVE CONCRETE POLE,
DIRECT BURIED (8.38m)

REV No.	DATE
2	MAY 2020
SCALE: N.T.S.	

BSD-829