



NOTES:

1. NOT TO BE USED IN AREAS WITH HIGH POTENTIAL OF CONTAMINATED RUNOFF.
2. BASE OF SOAKAWAY PIT SHALL BE A MINIMUM OF 1.0m BELOW BUILDING FOOTING, AND A MINIMUM OF 5.0m FROM THE STRUCTURE IN ACCORDANCE WITH THE ONTARIO BUILDING CODE
3. SITING AND GRADES SHALL BE IN ACCORDANCE WITH THE CITY OF BARRIE LOT GRADING GUIDELINES.
4. A MINIMUM OF 1.0m SEPARATION FROM HIGHWATER TABLE REQUIRED.
5. REFER TO SECTION 4.5.6 OF THE MOE SWM PLANNING AND DESIGN MANUAL FOR DESIGN PARAMETER.
6. THE INFILTRATION/SOAKAWAY PITS & ROOF TOP INFILTRATION TRENCHES TO BE CONSTRUCTED LAST (AFTER HOME CONSTRUCTION) TO PREVENT SEDIMENT CLOGGING & COMPACTION DURING CONSTRUCTION ACTIVITIES.