



NOTES:

1. NOT TO BE USED IN AREAS WITH HIGH POTENTIAL OF CONTAMINATED RUNOFF.
2. BASE OF SOAKAWAY PIT SHALL BE A MINIMUM OF 1.0m BELOW BUILDING FOOTING, AND A MINIMUM OF 5.0m FROM THE STRUCTURE IN ACCORDANCE WITH THE ONTARIO BUILDING CODE
3. SITING AND GRADES SHALL BE IN ACCORDANCE WITH THE CITY OF BARRIE LOT GRADING AND DRAINAGE INFRASTRUCTURE STANDARDS.
4. A MINIMUM OF 1.0m SEPARATION FROM HIGHWATER TABLE REQUIRED.
5. REFER TO SECTION 4.5.6 OF THE MECP SWM PLANNING AND DESIGN MANUAL FOR DESIGN PARAMETER.
6. THE INFILTRATION/SOAKAWAY PITS & ROOF TOP INFILTRATION TRENCHES TO BE CONSTRUCTED LAST (AFTER HOME CONSTRUCTION) TO PREVENT SEDIMENT CLOGGING & COMPACTION DURING CONSTRUCTION ACTIVITIES.



Lot Drainage Soakaway Pit

REV No.	DATE: APR 2023
3	SCALE: N.T.S

D709