



NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN
2. WORK ON HYDRO POLE SHALL BE DONE ONLY IN THE PRESENCE OF OR WITH THE PERMISSION OF THE LOCAL HYDRO AUTHORITY.
3. CO-ORDINATE THIS WORK WITH THE LOCAL HYDRO AUTHORITY, GIVING TWO WEEKS ADVANCED NOTICE AND INCORPORATING ANY MINOR CHANGES REQUIRED.
4. MOUNTING DETAILS SHOWN ARE TYPICAL ONLY AND SHALL BE ADAPTED TO SUIT SITE CONDITIONS AND THE LOCAL HYDRO AUTHORITY.
5. LEAVE SUFFICIENT CABLES COILED FOR CONNECTION TO SECONDARY, SECONDARY BUS OR TRANSFORMER BY LOCAL AUTHORITY.
6. CO-ORDINATE THE SUPPLY OF THE ASSET TAG WITH THE CITY OF BARRIE'S TRAFFIC SERVICES DEPARTMENT. ASSET TAG TO BE INSTALLED AS PER CONTRACT DRAWINGS AND AS DIRECTED BY THE CONTRACT ADMINISTRATOR IN CONSULTATION WITH TRAFFIC SERVICES.



POWER SUPPLY
POLE MOUNTED DETAIL

REV No.	DATE: APR 2024
3	SCALE: N.T.S.

R342