


NOTES: STEEL POLE METERED SUPPLY

STEEL POLE

WOOD OR CONCRETE POLE

1. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN
2. WORK ON HYDRO POLE SHALL BE DONE ONLY IN THE PRESENCE OF OR WITH THE PERMISSION OF THE LOCAL HYDRO AUTHORITY.
3. CO-ORDINATE THIS WORK WITH THE LOCAL HYDRO AUTHORITY, GIVING TWO WEEKS ADVANCED NOTICE AND INCORPORATING ANY MINOR CHANGES REQUIRED.
4. MOUNTING DETAILS SHOWN ARE TYPICAL ONLY AND SHALL BE ADAPTED TO SUIT SITE CONDITIONS AND THE LOCAL HYDRO AUTHORITY.
5. LEAVE SUFFICIENT CABLES COILED FOR CONNECTION TO SECONDARY, SECONDARY BUS OR TRANSFORMER BY LOCAL AUTHORITY.
6. FOR TRAFFIC SIGNAL CONTROLLER CABINET MOUNTING DETAILS, SEE R350.
7. THE CITY SHALL SUPPLY ASSET TAG(S) AND THE CONTRACTOR SHALL CO-ORDINATE THE SUPPLY OF THE ASSET TAG WITH THE CITY OF BARRIE'S TRAFFIC SERVICES DEPARTMENT. THE ASSET TAG SHALL BE INSTALLED AS PER CONTRACT DRAWINGS AND AS DIRECTED BY THE CONTRACT ADMINISTRATOR IN CONSULTATION WITH TRAFFIC SERVICES.



AERIAL POWER SUPPLY DETAIL

REV No. DATE: APR 2024

3

SCALE: N.T.S.

R343