



FRONT VIEW

SIDE VIEW

NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.
2. FOR POWER PEDESTAL BASE ASSEMBLY DETAILS, SEE R334.
3. CO-ORDINATE THIS WORK WITH THE LOCAL HYDRO AUTHORITY, GIVING TWO WEEKS ADVANCED NOTICE AND INCORPORATING ANY MINOR CHANGES REQUIRED.
4. LEAVE SUFFICIENT CABLES COILED FOR CONNECTION TO SECONDARY, SECONDARY BUS OR TRANSFORMER BY LOCAL AUTHORITY. EACH CABLE MUST BE ONE CONTINUOUS PIECE WITH NO SPLICES.
5. THE PEDESTAL SHALL BE SET AND SECURED IN PLACE ON BASE, RIGID, PLUMB AND SQUARE TO SURROUNDINGS. THE PANEL COVER SHALL BE INSTALLED FACING AWAY FROM THE INTERSECTION UNLESS OTHERWISE IDENTIFIED BY THE CONTRACT ADMINISTRATOR.
6. THE CONTRACTOR SHALL CO-ORDINATE THE SUPPLY OF THE ASSET TAG WITH THE CITY OF BARRIE'S TRAFFIC SERVICES DEPARTMENT. THE ASSET TAG SHALL BE INSTALLED AS PER THE CONTRACT DRAWINGS AND AS DIRECTED BY THE CONTRACT ADMINISTRATOR IN CONSULTATION WITH TRAFFIC SERVICES.
7. ENCLOSURE SHALL BE POWDER COATED BLACK FOR LOCATIONS SPECIFIED WITHIN THE DOWNTOWN AREA AS DEFINED IN THE CITY'S OFFICIAL PLAN.



POWER SUPPLY PEDESTAL
BASE MOUNTED

REV No.	DATE: APR 2024
3	SCALE: N.T.S.

R344