



NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.
2. FOR POLE DETAILS, SEE R360.
3. POLES SHALL BE PLACED SO THAT HANDHOLE ORIENTATIONS ARE IN ACCORDANCE WITH OPSD 2220.01.
4. CONCRETE IN FOUNDATION SHALL BE PLACED AGAINST UNDISTURBED GROUND.
5. TOP OF FOUNDATION SHALL BE TRULY LEVEL.
6. CLASS OF CONCRETE TO BE MIN. 30 MPa.
7. ALL FOOTINGS WILL BE VIBRATED DURING CONCRETE POUR.
8. SLEEVES SHALL BE 50 I.D., 90° BEND, RIGID PVC CONDUIT.
9. BOLTS SHALL BE FACTORY SET IN FERRULE, HAND TIGHTENED WITH ANTI SEIZE COMPOUND.
10. DIRECTION OF CONDUIT SLEEVE ENTRY TO BE MARKED WITH AN 'X'.
11. THE CONTRACTOR SHALL REVIEW THE LAYOUT DRAWINGS FOR THE ORIENTATION & LOCATION OF THE ACCESSIBLE PEDESTRIAN SIGNAL TO THE APPROPRIATE DIRECTION OF THE PEDESTRIAN CROSSWALK.
12. WHEN POLES ARE RELOCATED DUE TO UTILITY CONFLICTS THE SIDEWALK BAY SHALL BE EXTENDED TO ENCOMPASS 50% OF THE POLE BASE.



PEDESTRIAN
PUSHBUTTON POLE (1.5m)
BASE MOUNTED

REV No. DATE: APR 2024

3

SCALE: N.T.S.

R358