




TYPICAL PLAN



POLE FOUNDATION IN CUT



POLE FOUNDATION IN FILL



POLE FOUNDATION ADJACENT TO SIDEWALK

NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.
2. FOR OFFSET, BURIAL DEPTH AND POLE TYPE, SEE CONTRACT DRAWINGS.
3. BURIAL DEPTH SHALL BE MEASURED FROM THE HIGHEST GRADE ELEVATION AT POLE FOUNDATION.
4. TOP OF POLE FOUNDATION TO BE AT GRADE WITHIN 300MM OF SIDEWALK.



POLE FOUNDATION GRADING

REV No.	DATE: APR 2023
2	SCALE: N.T.S.

R359