



Notes

1. Any junction made in a service pipe between main stop and curb stop is to be made with approved couplings (for 50mm services only).
2. All water services are to be installed at a right angle to the watermain.
3. All tappings are to be at a 3 or 9 o'clock position only.
4. 915mm (36") stainless steel service box rod required.
5. See drawing W504 for 38mm and 50mm non-copper water services.
6. All dimensions are in millimetres unless otherwise shown.



Water Service
Copper 38mm & 50mm

REV No.

3

DATE: Sept 2024

SCALE: N.T.S.

W503