



NOTES

1. ANY JUNCTION MADE IN SERVICE PIPE BETWEEN MAIN STOP AND CURB STOP TO BE MADE WITH APPROVED COUPLINGS. (FOR 50mm ONLY).
2. ALL WATER SERVICES TO BE INSTALLED AT RIGHT ANGLE TO THE WATERMAIN.
3. ALL TAPPINGS TO BE AT 3 OR 9 O'CLOCK POSITION ONLY.
4. 915mm (36") STAINLESS STEEL SERVICE BOX ROD.
5. SEE BSD-504 FOR 38mm AND 50mm NON-COPPER WATER SERVICES.
6. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN.



**Water Service
Copper 38mm & 50mm**

REV No.

DATE: APR 2023

2

SCALE: N.T.S.

W503