



NOTES:

1. EXTENSION REQUIRED WHEN DISTANCE FROM THE TOP OF VALVE TO FINISHED GRADE IS MORE THAN 1.7m.



Valve Stem Extension

REV No.

3

DATE: MAY 2024

SCALE: N.T.S

W511