



NOTES:

1. MATERIAL FOR LOWERING SHALL BE DUCTILE IRON IF EXISTING MATERIAL IS METALLIC.
2. UNITS IN MILLIMETERS UNLESS OTHERWISE NOTED.
3. ALL JOINTS TO BE MECHANICALLY RESTRAINED, INCLUDING JOINTS ON EXISTING WATERMAIN.

SECTION A - A



Watermain Sanitary Separation

REV No. DATE: APR 2023

2

SCALE: N.T.S

W518