



**NOTES:**

1. MINIMUM CHAMBER SIZE 1800mmx2400mm
2. APPLICATION: NON-PRESSURE REDUCING VALVE CHAMBERS ONLY
3. WATERPROOF MEMBRANE TO EXTEND COMPLETELY AROUND RISER SECTION JOINTS WITH A MINIMUM OF 300mm WIDE STRAP.
4. ALL INSULATION TO BE RIGID TYPE EXTRUDED POLYSTYRENE FOAM DOW HI-40 OR HI-100. ALL CHAMBER INSULATIONS TO BE INSTALLED WITH CONSTRUCTION ADHESIVE AND TAPCON ANCHORS AT MAX. 600mm SPACING IN ALL DIRECTIONS (MIN. 2 ANCHORS PER SHEET OF INSULATION).
5. SUMP c/w GRATE TO BE LOCATED AT THE BOTTOM OF THE ACCESS LADDER. SUMP SHALL NOT EXTEND THROUGH THE BOTTOM OF BASE.

**ACCESS RISER INSULATION SECTION DETAIL**

	<h2 style="margin: 0;">Chamber</h2> <h3 style="margin: 0;">Pre-Cast Rectangular</h3>	REV No. <span style="font-size: 2em; font-weight: bold;">3</span>	DATE: APR 2023  SCALE: N.T.S
	W525		