



**NOTES:**

1. MIN 300mm CLEAR SPACE REQUIRED FROM CENTER OF METER TO EXTERIOR WALL (ONE WALL), MIN 600mm CLEAR SPACE REQUIRED (THREE SIDES)
2. AVERAGE SIZE PERSON SHOULD BE ABLE TO ACCESS METER
3. PROVIDE SUPPORT FOR THE WATER SERVICE AND PLUMBING, AS REQUIRED
4. METER WIRE TO BE BROUGHT TO OUTSIDE OF BUILDING, 1.2m TO 1.5m ABOVE FINAL GRADE, AND BE LOCATED BESIDE HYDRO METER OR ON NEAREST EXTERIOR WALL TO WATER METER IF HYDRO METER IS UNAVAILABLE
5. NO CONNECTIONS PERMITTED UPSTREAM OF WATER METER AND BACKFLOW PREVENTER
6. METER TO BE INSPECTED AND SEALED PRIOR TO OCCUPANCY, CALL WATER OPERATIONS BRANCH FOR INSPECTION AND SEAL OF WATER METER
7. PIPING SUPPORT REQUIRED TO THE SATISFACTION OF THE CITY OF BARRIE
8. WATER METERS LOCATED IN A CRAWL SPACE, UNDER STAIR LANDING, IN WALLS OR OTHER INACCESSIBLE AREAS WILL NOT BE ACCEPTED
9. A FLAT SURFACE MUST BE PROVIDED FOR THE INSTALLATION OF THE EXTERIOR REMOTE READING DEVICE (SMARTPOINT). STUCCO EXTERIOR REQUIRES WOOD BLOCKING AT THE SMARTPOINT LOCATION
10. THERMAL EXPANSION TANK TO BE INSTALLED ON A COLD WATER LINE AND THE AIR PRESSURE IN THE BLADDER CHARGED EQUAL TO STATIC LINE PRESSURE



# Residential Water Meter Installation Package

REV No.	DATE: SEPT 2023
<b>5</b>	SCALE: N.T.S

**W532**