



NOTES:

1. MIN 300mm CLEAR SPACE REQUIRED FROM CENTER OF METER TO EXTERIOR WALL (ONE WALL), MIN 600mm CLEAR SPACE REQUIRED (THREE SIDES)
2. AVERAGE SIZE PERSON SHOULD BE ABLE TO ACCESS METER
3. PROVIDE SUPPORT FOR THE WATER SERVICE AND PLUMBING, AS REQUIRED
4. NO CONNECTIONS PERMITTED UPSTREAM OF THE WATER METER AND BACKFLOW PREVENTER
5. METER TO BE INSPECTED AND SEALED PRIOR TO OCCUPANCY, CALL WATER OPERATIONS BRANCH FOR ALL INSPECTION AND SEAL OF WATER METER
6. PIPING SUPPORT REQUIRED TO THE SATISFACTION OF THE CITY OF BARRIE
7. WATER METERS LOCATED IN A CRAWL SPACE, UNDER STAIR LANDING, IN WALLS OR OTHER INACCESSIBLE AREAS WILL NOT BE ACCEPTED
8. A FLAT SURFACE MUST BE PROVIDED FOR THE INSTALLATION OF THE EXTERIOR REMOTE READING DEVICE (SMARTPOINT). STUCCO EXTERIOR REQUIRED WOOD BLOCKING AT THE SMARTPOINT LOCATION
9. METER WIRE, INSTALLED IN CONDUIT, TO BE RUN FROM METER LOCATION TO OUTSIDE OF BUILDING, 1.2m TO 1.5m ABOVE FINAL GRADE, AT THE DIRECTION OF THE CITY OF BARRIE WATER OPERATIONS REPRESENTATIVE. METER WIRE (22 GAUGE, 2 CONDUCTOR, METGRAY, UV RATED) TO BE SUPPLIED BY THE CITY OF BARRIE
10. BACKFLOW PREVENTER MUST BE INSTALLED WITHIN A MAXIMUM OF 3 METERS DOWNSTREAM OF THE WATER METER



Water Meter Installation

19mm to 25mm General Service

REV No. DATE: SEPT 2023

1

SCALE: N.T.S

W540