



## **FIRE PREVENTION MEASURES**

- All exits, aisles, exist signs, emergency lighting units, fire alarm pull stations, fire extinguishers, hose cabinets, sprinklers, Fire Department access routes, pumper connections, and hydrants must be unobstructed at all times.
- Drapes, curtains, and other decorative textiles must meet NFPA 701 for flame resistance.
  - Provide documentation to the Fire Department
- No open flames are permitted
- No combustibles such as hay, straw, shavings, wood chips, etc. are permitted
- BBQ's to be 3m (10') from structures
  - A valid propane certificate is required
- Music or theatrical performances are to be shut down in the event of an emergency
- A telephone must be provided on-site for emergency notification of #911
- A Maximum Occupant Load sign is required if more than 60
- Install NO SMOKING signs throughout the tent
- Mount 10 lb. ABC fire extinguishers at all required exits
- Fire watch to be implemented if more than 150 person (see below)

### **A PERSON EMPLOYED FOR FIREWATCH MUST:**

- Patrol the area and ensure all fire prevention measures are enforced
- If windowless or after dark hours, have flashlights on scene to assist with exiting in the event of a power failure
- Have a system to notify occupants of an emergency if no fire alarm is present (i.e. a P.A. system or bull horn)
- Call #911 to report an emergency and provide: address, name, and call back number

**A COPY OF THESE MEASURES MUST BE MAINTAINED ON-SITE**